MEMORANDUM

5-6

REFER		NOTED	
TO	DATE	BY	DATE
RETURN TO		FILE	

TO: Mr. F. H. Werneke, Assistant Construction Manager, WTC
FROM: A. J. Calabrese
DATE: March 4, 1968
SUBJECT: WORLD TRADE CENTER - INSPECTION OF FIREPROOFING

REFERENCE:

COPY TO: Messrs. Calabrese, Druding, Magrath; File

The following is a chronological listing of events relative to the application of the Cafco fireproofing:

1. Started application at 11:00 a.m. on January 29, 1968 - Weather, 36° F. and rain.

2. Weather during the night of January 29, 1968 - high winds - rain - snow. Temperature dropped from 36° F. at time of application to 24° F. at 6:00 a.m. on March 1, 1968.

3. Checked Cafco material at 7:00 a.m. on March 1, 1968. Material was wet, but firm and in place.

Present at installation:

Mario & D'Bono - Louis D'Bono
Cafco - Nessimer & Gropp
Port of New York Authority - Messrs. Werneke, Calabrese
Tishman - Mr. M. Altman
Emory Roth representative

A. J. Calabrese
Construction Inspector IV

AJC/eap

THE PORT OF NEW YORK AUTHORITY
OFFICE OF CONSTRUCTION MANAGER
RECEIVED
MAR 4 1968
PLANNING & CONSTRUCTION DIVISION

PLAINTIFF'S EXHIBIT
PX-488